




CERTIFICATE

No. Z2 140216 0001 Rev. 00

Holder of Certificate: **NANTONG GAMKO NEW ENERGY CO.,LTD.**
10 #-B-1F,NO. 606, KAIFA AVENUE
DAGONG SCI&TECH INDUSTRIAL PARK
HAIAN COUNTY
226006 NANTONG
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262618901-00

Valid until: 2031-02-05

Date, 2026-09-11


(Zhulin Zhang)



CERTIFICATE

No. Z2 140216 0001 Rev. 00

Model(s):

GKAXxx, xxx=665 to 755, in steps of 5,
 GKAXxx-HD-DG, xxx=610 to 685, in steps of 5,
 GKAXxx-HE-DG, xxx=555 to 630, in steps of 5,
 GKAXxx-HG-DG, xxx=505 to 570, in steps of 5,
 GKAXxx-HI-DG, xxx=400 to 460, in steps of 5,
 GKAXxx-NC-DG, xxx=665 to 750, in steps of 5,
 GKAXxx-ND-DG, xxx=605 to 680, in steps of 5,
 GKAXxx-NE-DG, xxx=555 to 625, in steps of 5,
 GKAXxx-NG-DG, xxx=500 to 570, in steps of 5,
 GKAXxx-NI-DG, xxx=400 to 455, in steps of 5,
 GKAXxx-NC-SG, xxx=665 to 730, in steps of 5,
 GKAXxx-ND-SG, xxx=605 to 665, in steps of 5,
 GKAXxx-NE-SG, xxx=555 to 610, in steps of 5,
 GKAXxx-NG-SG, xxx=500 to 555, in steps of 5,
 GKAXxx-NI-SG, xxx=400 to 445, in steps of 5,
 GKAXxx-NRC-DG, xxx=600 to 650, in steps of 5,
 GKAXxx-NRD-DG, xxx=545 to 590, in steps of 5,
 GKAXxx-NRF-DG, xxx=485 to 530, in steps of 5,
 GKAXxx-NRH-DG, xxx=430 to 475, in steps of 5,
 GKAXxx-NEB-DG, xxx=595 to 625, in steps of 5,
 GKAXxx-NED-DG, xxx=490 to 520, in steps of 5,
 GKAXxx-NEF-DG, xxx=440 to 470, in steps of 5,
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed with Junction box, Cable and Connectors; Framed, double glass with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

Tested according to:

IEC 61215-1:2021
 IEC 61215-1-1:2021
 IEC 61215-2:2021
 IEC 61730-1:2016
 IEC 61730-2:2016