



Attestation of Conformity

No. N8A 140216 0002 Rev. 00

Holder of Attestation: **NANTONG GAMKO NEW ENERGY CO.,LTD.**

10 #-B-1F,NO. 606, KAIFA AVENUE
DAGONG SCI&TECH INDUSTRIAL PARK
HAIAN COUNTY
226006 NANTONG
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062681001-00

Date, 2026-09-11

(Zhulin Zhang)

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Attestation of Conformity

No. N8A 140216 0002 Rev. 00

Model(s):

GKAxxx, xxx=665 to 755, in steps of 5,
 GKAxxx-HD-DG, xxx=610 to 685, in steps of 5,
 GKAxxx-HE-DG, xxx=555 to 630, in steps of 5,
 GKAxxx-HG-DG, xxx=505 to 570, in steps of 5,
 GKAxxx-HI-DG, xxx=400 to 460, in steps of 5,
 GKAxxx-NC-DG, xxx=665 to 750, in steps of 5,
 GKAxxx-ND-DG, xxx=605 to 680, in steps of 5,
 GKAxxx-NE-DG, xxx=555 to 625, in steps of 5,
 GKAxxx-NG-DG, xxx=500 to 570, in steps of 5,
 GKAxxx-NI-DG, xxx=400 to 455, in steps of 5,
 GKAxxx-NC-SG, xxx=665 to 730, in steps of 5,
 GKAxxx-ND-SG, xxx=605 to 665, in steps of 5,
 GKAxxx-NE-SG, xxx=555 to 610, in steps of 5,
 GKAxxx-NG-SG, xxx=500 to 555, in steps of 5,
 GKAxxx-NI-SG, xxx=400 to 445, in steps of 5,
 GKAxxx-NRC-DG, xxx=600 to 650, in steps of 5,
 GKAxxx-NRD-DG, xxx=545 to 590, in steps of 5,
 GKAxxx-NRF-DG, xxx=485 to 530, in steps of 5,
 GKAxxx-NRH-DG, xxx=430 to 475, in steps of 5,
 GKAxxx-NEB-DG, xxx=595 to 625, in steps of 5,
 GKAxxx-NED-DG, xxx=490 to 520, in steps of 5,
 GKAxxx-NEF-DG, xxx=440 to 470, in steps of 5,
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed with Junction box, Cable and Connectors; Framed, double glass with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06